


Supplement 1-2003
to
ASME A112.19.14-2001
Six-Liter Water Closets Equipped With a Dual Flushing Device

(This Supplement was approved as an American National Standard on June 20, 2003.)

Paragraph 3.2.4.2 has been revised. The revised paragraph appears below.

3.2.4.2 Performance Requirement. A dilution ratio of at least 17:1 shall be obtained in each initial flush, for the average of the three tests. The procedure shall be repeated until three sets of data are obtained.

Copyright © 2003
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
Three Park Avenue, New York, NY 10016-5990
All Rights Reserved



J0165A

SIX-LITER WATER CLOSETS EQUIPPED WITH A DUAL FLUSHING DEVICE

AN AMERICAN NATIONAL STANDARD



The American Society of
Mechanical Engineers



The American Society of
Mechanical Engineers

A N A M E R I C A N N A T I O N A L S T A N D A R D

SIX-LITER WATER CLOSETS EQUIPPED WITH A DUAL FLUSHING DEVICE

ASME A112.19.14-2001

Date of Issuance: August 1, 2002

This Standard will be revised when the Society approves the issuance of a new edition. There will be no addenda to this edition.

ASME issues written replies to inquiries concerning interpretations of technical aspects of this Standard.

ASME is the registered trademark of The American Society of Mechanical Engineers.

This code or standard was developed under procedures accredited as meeting the criteria for American National Standards. The Standards Committee that approved the code or standard was balanced to assure that individuals from competent and concerned interests have had an opportunity to participate. The proposed code or standard was made available for public review and comment that provides an opportunity for additional public input from industry, academia, regulatory agencies, and the public-at-large.

ASME does not "approve," "rate," or "endorse" any item, construction, proprietary device, or activity.

ASME does not take any position with respect to the validity of any patent rights asserted in connection with any items mentioned in this document, and does not undertake to insure anyone utilizing a standard against liability for infringement of any applicable letters patent, nor assumes any such liability. Users of a code or standard are expressly advised that determination of the validity of any such patent rights, and the risk of infringement of such rights, is entirely their own responsibility.

Participation by federal agency representative(s) or person(s) affiliated with industry is not to be interpreted as government or industry endorsement of this code or standard.

ASME accepts responsibility for only those interpretations of this document issued in accordance with the established ASME procedures and policies, which precludes the issuance of interpretations by individuals.

No part of this document may be reproduced in any form,
in an electronic retrieval system or otherwise,
without the prior written permission of the publisher.

The American Society of Mechanical Engineers
Three Park Avenue, New York, NY 10016-5990

Copyright © 2002 by
THE AMERICAN SOCIETY OF MECHANICAL ENGINEERS
All Rights Reserved
Printed in U.S.A.

*In memory of, and dedicated to the life of,
our dear friend, colleague, and long-standing leader,
Patrick J. Higgins.*

CONTENTS

Foreword	vi
Standards Committee Roster	vii
Correspondence With the A112 Committee	ix
1 General	1
2 Requirements	1
3 Testing	1
4 Marking	3

FOREWORD

In 1992, the Federal Energy Policy Act was enacted into law by Congress. This Act not only addressed energy issues but also included criteria for water conservation products in the United States that became effective in January 1994. As a complement to the enactment of this Act, the plumbing industry had already developed numerous water-efficient plumbing products that improved the performance of 1.6 gal per flush water closets.

One recent advance in the development of water closets is the use of dual flush technology that allows the consumer to flush with either a short flush, 1.10 gal (4.1 L) or less, or a long or full 1.6 gal (6 L) flush, depending upon need. This Standard addresses the performance of these products.

This Standard establishes test criteria for 1.6 gal (6 L) dual flush water closets. It was prepared by an ad hoc committee from the International Association of Plumbing and Mechanical Officials (IAPMO). It was then referred to ASME and assigned to the A112 Project Team 19.14. It was subsequently reviewed and approved by the ASME A112 Standards Committee.

Suggestions for the improvement of this Standard are welcome. They should be addressed to The American Society of Mechanical Engineers, Secretary, A112 Standards Committee, Three Park Avenue, New York, NY 10016-5990.

This Standard was approved as an American National Standard on June 20, 2001.

ASME STANDARDS COMMITTEE A112

Standardization of Plumbing Materials and Equipment

(The following is the roster of the Committee at the time of approval of this Standard.)

OFFICERS

P. J. Higgins, *Chair*
S. A. Remedios, *Vice Chair*
C. J. Gomez, *Secretary*

COMMITTEE PERSONNEL

R. H. Ackroyd, Consultant
J. S. Aiello, Jacuzzi Whirlpool Bath
J. A. Ballanco, JB Engineering & Code Consulting
S. L. Cavanaugh, United Association
A. Cohen, Arthur Cohen and Associates
P. V. DeMarco, American Standard, Inc.
N. Covino, *Alternate*, American Standard, Inc.
G. S. Duren, Code Compliance, Inc.
R. Emmerson, Chicago Faucets Co.
F. C. Evans, Consultant
L. S. Galowin, National Institute of Standards and Technology
C. J. Gomez, The American Society of Mechanical Engineers
R. I. Greenwald, Sunroc Corp.
G. Gress, BOCA International
J. P. Gronewold, NSF International
P. J. Higgins, PJ Higgins & Associates, Inc.
D. E. Holloway, SGS US Testing Co.
M. Klimboff, Consultant
M. T. Kobel, IAPMO
J. W. Lauer, Sloan Valve Co.
R. M. Martin, California Energy Commission
P. Meikie, Underwriters Laboratories, Inc.
L. M. Kriegbaum, *Alternate*, Underwriters Laboratories, Inc.
L. A. Mercer, Moen, Inc.
S. Rawalpindiwala, Kohler Co.
J. A. Sargent, *Alternate*, Kohler Co.
S. A. Remedios, Delta Faucet Co.
G. L. Simmons, Charlotte Pipe and Foundry
W. M. Smith, Jay R. Smith Manufacturing Co.
D. W. Viola, Plumbing Manufacturers Institute
R. E. White, Richard E. White & Associates
W. C. Whitehead, Plumbing & Drainage Institute

PERSONNEL OF A112 PROJECT TEAM 19.14 — DUAL FLUSH FOR 6-LITER WATER CLOSETS

J. A. Sargent, *Project Team Leader*, Kohler Co.

O. Dufau, Fluidmaster

P. J. Higgins, PJ Higgins & Associates, Inc.

M. T. Kobel, IAPMO

J. Koeller, Koeller and Co.

W. P. McDonnell, Los Angeles Metropolitan Water District

J. R. Paschal, NSF International

S. Rawalpindiwala, Kohler Co.

CORRESPONDENCE WITH THE A112 COMMITTEE

General: ASME Standards are developed and maintained with the intent to represent the consensus of concerned interests. As such, users of this Standard may interact with the Committee by requesting interpretations, proposing revisions, and attending Committee meetings. Correspondence should be addressed to:

Secretary, A112 Standards Committee
The American Society of Mechanical Engineers
Three Park Avenue
New York, NY 10016-5990

Proposing Revisions. Revisions are made periodically to the Standard to incorporate changes that appear necessary or desirable, as demonstrated by the experience gained from the application of the Standard. Approved revisions will be published periodically.

The Committee welcomes proposals for revisions to this Standard. Such proposals should be as specific as possible, citing the edition, the paragraph number(s), the proposed wording, and a detailed description of the reasons for the proposal, including any pertinent documentation. When appropriate, proposals should be submitted using the A112 Project Initiation Request Form.

Interpretations. Upon request, the A112 Committee will render an interpretation of any requirement of the Standard. Interpretations can only be rendered in response to a written request sent to the Secretary of the A112 Standards Committee.

The request for interpretation should be clear and unambiguous. It is further recommended that the inquirer submit his/her request in the following format:

Subject:	Cite the applicable paragraph number(s) and the topic of the inquiry.
Edition:	Cite the applicable edition of the Standard for which the interpretation is being requested.
Question:	Phrase the question as a request for an interpretation of a specific requirement suitable for general understanding and use, not as a request for an approval of a proprietary design or situation. The inquirer may also include any plans or drawings that are necessary to explain the question; however, they should not contain proprietary names or information.

Requests that are not in this format will be rewritten in this format by the Committee prior to being answered, which may inadvertently change the intent of the original request.

ASME procedures provide for reconsideration of any interpretation when or if additional information that might affect an interpretation is available. Further, persons aggrieved by an interpretation may appeal to the cognizant ASME Committee or Subcommittee. ASME does not "approve," "certify," "rate," or "endorse" any item, construction, proprietary device, or activity.

Attending Committee Meetings. The A112 Standards Committee schedules meetings as needed, which are open to the public. Persons wishing to attend any meeting should contact the Secretary of the A112 Standards Committee.

SIX-LITER WATER CLOSETS EQUIPPED WITH A DUAL FLUSHING DEVICE

1 GENERAL

1.1 Scope

This Standard establishes physical, material, testing, and marking requirements for six-liter water closets that incorporate a water-conserving dual flushing feature into the design of the fixture. The tests specified in this Standard are for removal of liquid wastes and toilet tissue or other comparable waste loads that are expected when actuating the reduced flush feature of the unit. The use of alternate materials or methods is permitted, provided that the proposed material and method comply with the performance requirements and the intent of this Standard.

1.2 Units of Measurement

Values are stated in U.S. Customary units and the International System of Units (SI). The U.S. Customary units shall be considered as the standard.

1.3 Reference Standards

The following documents form a part of this Standard to the extent specified herein (the latest issue shall apply):

ANSI Z124.4, Plastic Water Closet Bowls and Tanks
Publisher: International Association of Plumbing and Mechanical Officials (IAPMO), 20001 East Walnut Drive, South Walnut, CA 91789-2825

ASME A112.19.2M, Vitreous China Plumbing Fixtures
ASME A112.19.6, Hydraulic Requirements for Water Closets and Urinals

Publisher: The American Society of Mechanical Engineers (ASME), Three Park Avenue, New York, NY 10016-5990; Order Department, 22 Law Drive, Fairfield, NJ 07007-2900.

1.4 Definitions

dual flush: a feature that allows the user to flush the water closet with either a reduced or full volume of water, depending upon bowl contents.

low-consumption water closet: a water closet having an average water consumption (total flush volume) less than or equal to 1.6 gal (6 L) over the range of test pressures as specified in ASME A112.19.6 for each water closet type, and not exceeding 2.0 gal (7.6 L) at any one test pressure (based upon average values from the three run test).

2 REQUIREMENTS

2.1 Operation

The dual flush mechanism shall function by actuation and release of the selector control, switch, or handle and shall complete its cycle without requiring further action or holding by the user.

2.2 Water Closets

Water closets equipped with dual flush features shall conform to the requirements of ASME A112.19.2M or ANSI Z124.4.

3 TESTING

3.1 Full Flush Mode

Water closets equipped with dual flush features shall meet all the requirements of ASME A112.19.6 for low-consumption water closets when the full flush volume is activated.

3.2 Reduced Flush Mode

3.2.1 Trap Seal Restoration Test. The water closet as tested in paras. 3.2.2 through 3.2.5 shall also meet the performance requirements of para. 7.1.6.3 of ASME A112.19.6.

3.2.2 Reduced Flush Volume Test. The reduced flush volume shall not exceed 1.10 gal (4.1 L) per flush when tested in accordance with para. 7.1.6 of ASME A112.19.6. This testing shall be conducted before the durability testing in para. 3.2.6. The same

testing shall be conducted after the durability testing in para. 3.2.6 and the reduced volume shall not vary more than 0.11 gal (0.41 L).

3.2.3 Rim Wash Test. The water closet shall use the test methods and meet the performance requirements of para. 7.1.4 of ASME A112.19.6, when in the reduced flush cycle.

3.2.4 Dye Test

3.2.4.1 Test Method

(a) 0.18 oz (5 g) of methylene blue powder shall be added to 0.26 gal (1 L) of water and mixed thoroughly in a clean container.

(b) The water closet under test shall be flushed once and allowed to complete its filling cycle. One fluid ounce (30 mL) of the dye solution shall be added to the water in the bowl and mixed thoroughly.

(c) 0.34 oz (10 mL) of this solution shall be removed from the bowl and shall be added to 16.9 oz (500 mL) of clean water in a suitable container (i.e., dilution ratio of 50:1). A sample of this solution shall be set aside in a test tube or comparator vial as the control sample.

(d) The water closet shall then be flushed several times to ensure that all traces of the dye solution have been removed. One 1 oz (30 mL) of the dye solution [see para. 3.2.4.1(a)] shall be added to the bowl. The flushing device shall be actuated and released in a normal manner and the test fixture shall be allowed to complete its filling cycle. A test tube or comparator vial shall be filled with water from the water closet bowl and compared against the control sample. The test shall be repeated two additional times and the results shall be averaged.

NOTE: Use of a spectrophotometer shall be permitted in case of doubt; however, this method shall necessitate the use of a different color dye.

3.2.4.2 Performance Requirement. A dilution ratio of at least 50:1 shall be obtained in each initial flush, for the average of the three tests. The procedure shall be repeated until three sets of data are obtained.

3.2.5 Toilet Paper Test

3.2.5.1 Test Media. The paper removal test in the reduced flush cycle shall be conducted as follows: the test load shall be composed of four balls of six sheets of untreated single-ply toilet paper, each crumpled into a loose ball measuring 2 in. to 3 in. (51 mm to 76 mm) in diameter. The standard size test sheet shall be 42 in. × 42 in. (114 mm × 114 mm).

The single-ply toilet paper shall first meet both the absorption and wet tensile strength requirements given in paras. 3.2.5.1.1 and 3.2.5.1.2, respectively.

3.2.5.1.1 Absorption

(a) *Test Method.* A six-sheet strip of the proposed toilet paper shall be obtained. The paper shall be wrapped snugly around a piece of 2 in. Schedule 40 PVC pipe. The paper shall be slid off the pipe. The tube of paper shall be grasped approximately halfway down its length and shall be turned inside out and down over itself. This shall result in a ball approximately 2 in. (51 mm) in diameter. The ball (straight edges down) shall be dropped into a pan of water. The time it takes for the ball to become fully saturated and sink below the water surface shall be recorded.

(b) *Performance Requirement.* The paper ball shall sink below the surface in less than 3 sec.

3.2.5.1.2 Wet Tensile Strength

(a) *Test Method.* A 2 in. Schedule 40 PVC coupling and union nut shall be used as a frame to hold the toilet paper for the wet tensile strength test. One sheet of the toilet paper on the coupling and the union nut shall be slid over the coupling. The frame shall be inverted and the paper shall be submerged in water for 5 sec. The frame shall then be removed from the water and shall be returned to an upright position. A 0.312 in. (8 mm) diameter steel ball weighing 6.3 ± 0.1 g shall be placed in the center of the wet sheet.

(b) *Performance Requirement.* The sheet shall support the steel ball without any evidence of tearing.

3.2.5.2 Test Method. The four 2 in. to 3 in. (51 mm to 76 mm) balls of paper that comply with paras. 3.2.5.1.1 and 3.2.5.1.2 shall be dropped into the water directly above the well and shall be allowed to wet out completely. Within 5 sec. after wetting occurs, the bowl shall be flushed. This procedure shall be repeated until three sets of data are obtained. Note whether any paper is left in the bowl. Flush again and collect any paper that discharges from the outlet.

3.2.5.3 Performance Requirement. No paper shall remain in the well after each initial flush.

3.2.6 Durability Test

3.2.6.1 Test Method. The water closet shall be cycled 15,000 cycles in the full volume flush mode and, after each four full flushes, one reduced flush shall be made followed by 60,000 cycles in the reduced volume flush mode.

3.2.6.2 Performance Requirement. At the completion of the test, the dual flush switch, actuator,

or levers shall show no sign of deterioration that would affect performance. They shall function smoothly and shall activate with a force of 5 lbf (22 N) or less.

4 MARKING

4.1 Identification of Flush Mode Options

Identification of flush mode options shall be depicted on the actuator. This identification shall be either by graphic display or lettering, or shall be intuitively apparent.

4.2 Water Closets

(a) The water closet shall be legibly marked as specified in ASME A112.19.2M or ANSI Z124.4, as appropriate.

(b) Water closets equipped with a dual flush device shall be marked with the reduced flush volume and the designation ASME A112.19.14 to signify compliance with this Standard. The location of this mark shall be determined by the manufacturer and is not required to be permanent, but it shall be visible after installation. The label shall be intended for removal by the occupant only, and shall be so stated on the label.

ASME STANDARDS RELATED TO PLUMBING

Air Gaps in Plumbing Systems.....	A112.1.2-1991(R1998)
Air Gap Fittings for Use With Plumbing Fixtures, Appliances, and Appurtenances	A112.1.3-2000
Performance Standard and Installation Procedures for Stainless Steel Drainage Systems for Sanitary, Storm, and Chemical Applications, Above and Below Ground	A112.3.1-1993
Macerating Toilet Systems and Related Components.....	A112.3.4-2000
Water Heater Relief Valve Drain Tubes	A112.4.1-1993(R1998)
Plastic Fittings for Connecting Water Closets to the Sanitary Drainage System	A112.4.3-1999
Floor-Affixed Supports for Off-the-Floor Plumbing Fixtures for Public Use.....	A112.6.1M-1997
Framing-Affixed Supports for Off-the-Floor Water Closets With Concealed Tanks	A112.6.2-2000
Floor and Trench Drains	A112.6.3-2001
Enameled and Epoxy Coated Cast Iron and PVC Plastic Sanitary Floor Sinks	A112.6.7-2001
Backwater Valves.....	A112.14.1-1975(R1998)
Grease Interceptors.....	A112.14.3-2000
Grease Removal Devices.....	A112.4.4-2001
Plumbing Fixture Fittings	A112.18.1-2000
Plumbing Fixture Waste Fittings	A112.18.2-2002
Performance Requirements for Backflow Protection Devices and Systems in Plumbing Fixture Fittings	A112.18.3M-1996
Flexible Water Connectors	A112.18.6-1999
Deck-Mounted Bath/Shower Transfer Valves With Integral Backflow Protection	A112.18.7-1999
Enameled Cast Iron Plumbing Fixtures	A112.19.1M-1994(R1999)
Vitreous China Plumbing Fixtures	A112.19.2M-1998
Stainless Steel Plumbing Fixtures (Designed for Residential Use).....	A112.19.3-2000
Porcelain Enameled Formed Steel Plumbing Fixtures.....	A112.19.4M-1994(R1999)
Trim for Water-Closet Bowls, Tanks, and Urinals	A112.19.5-1999
Hydraulic Performance Requirements for Water Closets and Urinals.....	A112.19.6-1995
Whirlpool Bathtub Appliances	A112.19.7M-1995
Suction Fittings for Use in Swimming Pools, Wading Pools, Spas, Hot Tubs, and Whirlpool Bathtub Appliances.....	A112.19.8M-1987(R1996)
Non-Vitreous Ceramic Plumbing Fixtures.....	A112.19.9M-1991(R1998)
Dual Flush Devices for Water Closets	A112.19.10-1994
Wall Mounted and Pedestal Mounted, Adjustable and Pivoting Lavatory and Sink Carrier Systems.....	A112.19.12-2000
Electrohydraulic Water Closets.....	A112.19.13-2001
Six-Liter Water Closets Equipped With a Dual Flushing Device.....	A112.19.14-2001
Bathtub/Whirlpool Bathtubs With Pressure Sealed Doors	A112.19.15-2001
Floor Drains	A112.21.1M-1991(R1998)
Roof Drains.....	A112.21.2M-1983
Hydrants for Utility and Maintenance Use	A112.21.3M-1985(R1995)
Cleanouts	A112.36.2M-1991(R1998)

The ASME Publications Catalog shows a complete list of all the Standards published by the Society. For a complimentary catalog, or the latest information about our publications, call 1-800-THE-ASME (1-800-843-2763).

ASME Services

ASME is committed to developing and delivering technical information. At ASME's Information Central, we make every effort to answer your questions and expedite your orders. Our representatives are ready to assist you in the following areas:

ASME Press
Codes & Standards
Credit Card Orders
IMechE Publications
Meetings & Conferences
Member Dues Status

Member Services & Benefits
Other ASME Programs
Payment Inquiries
Professional Development
Short Courses
Publications

Public Information
Self-Study Courses
Shipping Information
Subscriptions/Journals/Magazines
Symposia Volumes
Technical Papers

How can you reach us? It's easier than ever!

There are four options for making inquiries* or placing orders. Simply mail, phone, fax, or E mail us and an Information Central representative will handle your request.

Mail
ASME
22 Law Drive, Box 2900
Fairfield, New Jersey
07007-2900

Call Toll Free
US & Canada: 800-THE-ASME
(800-843-2763)
Mexico: 95-800-THE-ASME
(95-800-843-2763)
Universal: 973-882-1167

Fax—24 hours
973-882-1717
973-882-5155

E-Mail—24 hours
Infocentral@asme.org

* Information Central staff are not permitted to answer inquiries about the technical content of this code or standard. Information as to whether or not technical inquiries are issued to this code or standard is shown on the copyright page. All technical inquiries must be submitted in writing to the staff secretary. Additional procedures for inquiries may be listed within.

ISBN 0-7918-2776-3



9 780791 827765



J16501